

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245915

Address: 1402 SW WINTHROP TER, LEES SUMMIT, MO 640811400 SW WINTHROP TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Tuesday, June 10, 2025

Corrective Action Required:

2 Misc

-address ceiling joist to rafters connections missing(N and S exterior walls)  
-rear garage wall sill plate. Anchor bolts to be in the middle 1/3 of sill plate

1400

-missing nails in in hanger above bath 2  
-fire block W bath 2 wall to ceiling space  
-missing stud in stud pack E end LVL above kitchen  
-add stud under lvi bath2/entry wall  
-fire block bed 3 wall into furr down

1402

**Comments:**