



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20115556, Building Permit - Commercial  
Address: 130 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Electrical Inspection - Commercial</b>	John Borns	Partial	Tuesday, February 07, 2012

Partial Correction  
1 MISC

OK TO COVER WHEN READY: SIX 3/4" PVC CONDUITS FROM CHOIR LOFT AREA ALONG NW WALL OF NAVE TO RISERS @ WEST;

<b>Foundation Inspection - Commercial</b>	John Borns	Partial	Tuesday, February 07, 2012
-------------------------------------------	------------	---------	----------------------------

Partial Correction  
1 MISC

REPAIRS OF ANCHORAGE OF LAMINATED STRUCTURAL ARCHES: STRUCTURAL ASPECTS GUIDED & CERTIFIED BY ENGINEER OF RECORD. WEST / SOUTH / SOUTHEAST LOCATIONS POURED 2/7/12;

**Comments:**