

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242858

Address: 1426 SW WINTHROP TER, LEES SUMMIT, MO 640811424 SW WINTHROP TER, LEES SUMMIT, MO  
64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Jamie Simerly	Partial	Wednesday, June 11, 2025

Informational:

1 Misc

5-6-25 RH.

Sidewalk need poured on both side of Driveway. One side formed up other side is not graded yet.

06-11-25 Jamie S, SW is formed, compacted, and slopes are in compliance with city standards. Approved to Pour.

**Comments:**