

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20240118
Address: 515 NW MOORE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Partial	Wednesday, June 11, 2025

Informational:
1 Misc -Corridor ceiling joist space ok for RC all floors
Corrective Action Required:
2 Misc *Inspection for soffit framing at atriums:
3rd and 4th floor ok to cover

-Patch all rated ceilings, seal all penetrations

Comments: