

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20245128
Address: 3221 SW ARBORIDGE CIR, LEES SUMMIT, MO 64082
Inspected On: Wednesday, June 11, 2025
Inspected By: Development Center
Expiration Date: 6/11/2025 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Drew Fischer	Ready for Temp CO	Wednesday, June 11, 2025

Corrective Action Required:

1	Misc	-address pending driveway and sidewalk inspections -final grade and sod -splash blocks and sump pump discharge to extend 36" from foundation -address water meter pit missing ring and lid (ensure 14"-18" from top of meter to well ring lid, 2" min. Of gravel at bottom of meter well, clearance around meter for serviceability) -missing gutters
---	------	---

Corrective Action Required:

2	Misc	-address pending sidewalk inspection -splash blocks and sump pump discharge to extend 36" from foundation -address water meter pit missing ring and lid (ensure 14"-18" from top of meter to well ring lid, 2" min. Of gravel at bottom of meter well, clearance around meter for serviceability)
---	------	---

Occupancy Inspection - Codes Residential	Drew Fischer	Ready for Temp CO	Monday, May 12, 2025
---	--------------	-------------------	----------------------

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">-address pending driveway and sidewalk inspections-final grade and sod-splash blocks and sump pump discharge to extend 36" from foundation-address water meter pit missing ring and lid (ensure 14"-18" from top of meter to well ring lid, 2" min. Of gravel at bottom of meter well, clearance around meter for serviceability)-missing gutters |
|---|------|---|

Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Thursday, March 27, 2025
---	------------------	-------------------	--------------------------

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">-address pending driveway and sidewalk inspections-final grade and sod-splash blocks and sump pump discharge to extend 36" from foundation-address water meter pit missing ring and lid (ensure 14"-18" from top of meter to well ring lid, 2" min. Of gravel at bottom of meter well, clearance around meter for serviceability)-missing gutters |
|---|------|---|

Comments: