

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20250050  
Address: 1059 SW FIORD DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Wednesday, June 11, 2025

Informational:	
1 Misc	- PORTAL FRAME AND PORCH FRAMMING APPROVED ONLY
Corrective Action Required:	
2 Misc	- Damage trusses B2 in garage, upload engineer repair and complete
	Ok to insulate
Corrective Action Required:	
3 Miscellaneous Correction	PROVIDE LADDER FOR INSPECTION OF TRUSS REPAIR IN GARAGE

**Comments:**