

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232768
Address: 810 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Partial	Wednesday, June 11, 2025

Corrective Action Required:

1	Misc	G pre final 4th floor: 2425- seal fire sprinkler scone in front hallway 2427- missing fire sprinkler scone in living room 2432 - receptacle not GFCI protected kitchen counter far left of refrigerator
---	------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: