

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20246376
Address: 41 NE TUDOR RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Proof Roll	John Jackson	Partial	Wednesday, June 11, 2025

Informational:
1 Misc

06/06/25 Friday JMJ (Cityscape, CP)
Contractor passed proof roll for parking lot area Northeast section of project. Last week proof was was done passed for curbs that were installed on job location. Correction: 06/02/25 Monday proof roll for curb was passed and curbs were installed.

06/11/25 Wednesday JMJ
Contractor passed the proof roll. Third party was Kaw Valley. There was some deflection in three different valley point in parking lot area, but no rutting.

Comments: