

Report Email: dustin.agcopra@cityofls.net

Copy Email:

Lab Report Fax No:

Lab Report Contact 1: (816) 719-0718

Lab Report Contact 2:

Customer ID No: 9368

Customer PO No: Capitol Builders/ Flex

Collected By: Client

Invoice No: 64123

Dustin Agcopra
 Capitol Builders
 60 SE Thompson Dr

Lees Summit, MO 64082

Report of Analysis

Laboratory Report ID No:

20841

Project Name: Lee Summit Flex Space

Item No.	Cat NO	ANALYSIS	COLLECTED	ANALYZED	REPORTING LIMIT	RESULTS
	Line NO	SAMPLE TYPE	SAMPLE SITE NOTES		TEST METHOD	
1	6191	Bacteria, P/A E. Coli	6/5/25	6/6/25	1 CFU/100mL	Negative CFU/100mL
	140485	Grab	Spot 1		SM9223 B	
2	6190	Bacteria, P/A T. Coliform	6/5/25	6/6/25	1 CFU/100mL	Negative CFU/100mL
	140484	Grab	Spot 1		SM9223 B	

Comments, if present, concern this Lab Work Order:

The reported analytical results relate only to the sample submitted.

This report shall not be reproduced, except in full, without written approval by Blue Valley Laboratories, Inc.