

CITY OF LEE'S SUMMIT

CODES ADMINISTRATION DEPARTMENT

220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200
Fax (816) 969-1201

PLAN REVIEW CONDITIONS

February 07, 2012

LUTFI'S FISH AND CHICKEN
1196 NE DOUGLAS ST
LEE'S SUMMIT, MO 64086

Permit No: PRCOM20120156
Project Title: LUTFI'S FISH AND CHICKEN
Project Address: 1196 NE DOUGLAS ST, LEES SUMMIT, MO 64086
Parcel Number: 52910140600000000
Location: DOUGLAS STATION COMMERCIAL PARK LOTS 3-A, 4-A & 5-A---LOT 5-A
Type of Work: CHANGE OF TENANT
Occupancy Group: BUSINESS
Description: CHANGE OF TENANT, KITCHEN AND RESTROOMS EXISTING

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Michael Weisenborn

Approved

1. For the Health Department inspection contact Chris Saxton with the Jackson County Public Works Department, Environmental Health Division at 816-881-4455. Health Department approval is required prior to receiving any type of Occupancy from the City of Lee's Summit.

Action required - This comment is for information purposes.

3. 2006 IBC 1210.2 - Walls. Walls within 2 feet of urinals and water closets shall have a smooth, hard, nonabsorbent surface, to a height of 4 feet above the floor, and except for structural elements, the materials used in such walls shall be of a type that is not adversely affected by moisture. Exceptions: 1. Dwelling units and sleeping units. 2. Toilet rooms that are not accessible to the public and which have not more than one water closet. Accessories such as grab bars, towel bars, paper dispensers and soap dishes, provided on or within walls, shall be installed and sealed to protect structural elements from moisture.

Action required - To be verified on inspection.

Fire Plan Review

Reviewed By: Jim Eden

Approved

1. 2006 IFC 1004.3- Posting of occupant load. Every room or space that is an assembly occupancy shall have the occupant load of the room or space posted in a conspicuous place, near the main exit or exit access doorway from the

room or space. Posted signs shall be of an approved legible permanent design and shall be maintained by the owner or authorized agent.

Verified at inspection.

2. 2006 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

The hood suppression system shall have a current 67 month inspection tag and nozzles shall be adjusted or added to meet the requirements of the new appliances. Verified at inspection.

3. 2006 IFC 904.11.5- Portable fire extinguishers for commercial cooking equipment. Portable fire extinguishers shall be provided within a 30-foot (9144 mm) travel distance of commercial-type cooking equipment. Cooking equipment involving vegetable or animal oils and fats shall be protected by a Class K rated portable extinguisher.

Provide under the manual pull station for the hood suppression system. Verified at inspection.

4. 2006 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Provide a minimum of one 2A:10BC fire extinguisher at a conspicuous location. Verified at inspection.

_____ Approved to issue per the listed conditions.

_____ Do not issue per the listed conditions.

_____ Approved to construct foundation only per the listed conditions.

_____ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of Applicant

Date

Print Applicant Name

CompanyName

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.