



## Hydraulic Calculations by HydraCALC

Century Fire Sprinklers, Inc.  
1901 Bedford Ave,  
North Kansas City, MO 64116  
816-556-0808

Job Name : Lees Summit JOF  
Drawing : 1  
Location : 2 NE TUDOR RD - LEES SUMMIT, MO 64086  
Remote Area : 1  
Contract : KC1-1508  
Data File : Lees Summit JOF\_FS Lower Area 1.WXF



---

**HYDRAULIC CALCULATIONS**  
**for**

**JOB NAME** Lees Summit JOF  
**Location** 2 NE TUDOR RD - LEES SUMMIT, MO 64086  
**Drawing #** 1  
**Contract #** KC1-1508  
**Date** 05/07/2025

**DESIGN**

**Remote area #** 1  
**Remote area location** Lower Level - North Gen. Storage  
**Occupancy classification** O.H. 2  
**Density** 0.2 - Gpm/SqFt  
**Area of application** 1500 - SqFt  
**Coverage/sprinkler** 130 - SqFt  
**Type of sprinkler calculated** QR UPR 8.0K  
**# Sprinklers calculated** 16  
**In-rack demand** 0 - GPM  
**Hose streams** 250 - GPM  
**Total water required (including hose streams)** 712.955 - GPM @ 70.6618 - Psi  
**Type of system** WET  
**Volume of system (dry or pre-action)** 0 - Gal

**WATER SUPPLY INFORMATION**

**Test date** 08/15/2024  
**Location** NW Sloan between Main St. and NE Tudor Rd.  
**Source of info** SPEC. SECTION 211313

**CONTRACTOR INFO** Century Fire Sprinklers, Inc.  
**Address** 1901 Bedford Ave, / North Kansas City, MO 64116  
**Phone #** 816-556-0808  
**Name of designer** DJS  
**Authority having jurisdiction**

**NOTES:**

text1(35) - invisible

# Water Supply Curve

Century Fire Sprinklers, Inc.  
Lees Summit JOF


Page 2  
Date

## City Water Supply:

C1 - Static Pressure : 85  
C2 - Residual Pressure: 62  
C2 - Residual Flow : 2100

## Demand:

D1 - Elevation : -0.758  
D2 - System Flow : 462.955  
D2 - System Pressure : 70.662  
Hose ( Demand ) : 250  
D3 - System Demand : 712.955  
Safety Margin : 11.221



# Fittings Used Summary

Century Fire Sprinklers, Inc.  
Lees Summit JOF

Page 3  
Date

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
L	NFPA 13 Long Turn Elbow	0	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zca	Colt C200 Horiz	Fitting generates a Fixed Loss Based on Flow																			

## Units Summary

Diameter Units           Inches  
 Length Units             Feet  
 Flow Units                US Gallons per Minute  
 Pressure Units           Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Flow Summary - NFPA

Century Fire Sprinklers, Inc.  
Lees Summit JOF

Page 4  
Date

## SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	85.0	62	2100.0	81.883	712.96	70.662

## NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
105	98.25	8	10.65	26.1	0.2 130
106	98.25	8	10.96	26.48	0.2 130
107	98.25	8	11.63	27.28	0.2 130
108	98.25	8	11.63	27.29	0.2 130
109	98.25	8	11.94	27.64	0.2 130
T4	98.25		13.68		
110	97.67	8	14.18	30.12	0.2 130
111	97.67	8	14.43	30.39	0.2 130
112	97.67	8	15.34	31.33	0.2 130
T2	97.67		17.37		
113	97.5	8	16.32	32.32	0.2 130
114	97.5	8	16.78	32.77	0.2 130
T3	97.5		18.32		
115	98.08	8	21.35	36.96	0.2 130
116	96.71		22.4		
100	98.25	8	10.56	26.0	0.2 130
101	98.25	8	10.87	26.38	0.2 130
102	98.25	8	11.54	27.17	0.2 130
103	98.25	8	11.54	27.18	0.2 130
104	98.25	8	11.84	27.53	0.2 130
T5	98.25		13.58		
B5	96.71		19.3		
B4	96.71		19.44		
B3	96.71		19.9		
B2	96.71		20.17		
B1	96.71		22.85		
7	97.29		37.8		
6	95.5		44.26		
5	95.5		51.87		
4	94.88		53.1		
3	94.88		53.26		
2	94.88		55.05		
1	95.0		57.54		
BR1	87.0		64.84		
BF	87.0		72.22		
UG	90.0		72.05		
TEST	100.0		70.66	250.0	

# Final Calculations : Hazen-Williams

Century Fire Sprinklers, Inc.  
Lees Summit JOF

Page 5  
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
105 to 106	98.25 98.25	8.00	26.10 26.1	1.5 1.682			14.670 14.670	120 0.0214	10.645 0.0 0.314		Vel = 3.77	
106 to 107	98.25 98.25	8.00	26.48 52.58	1.5 1.682			8.550 8.550	120 0.0780	10.959 0.0 0.667		Vel = 7.59	
107 to T4	98.25 98.25	8.00	27.28 79.86	1.5 1.682	T	9.9	2.260 9.900 12.160	120 0.1692	11.626 0.0 2.057		Vel = 11.53	
T4			0.0 79.86						13.683		K Factor = 21.59	
108 to 109	98.25 98.25	8.00	27.29 27.29	1.5 1.682			13.000 13.000	120 0.0232	11.635 0.0 0.301		Vel = 3.94	
109 to T4	98.25 98.25	8.00	27.64 54.93	1.5 1.682	T	9.9	10.740 9.900 20.640	120 0.0846	11.936 0.0 1.747		Vel = 7.93	
T4 to B4	98.25 96.71		79.86 134.79	1.5 1.682	T	9.9	1.540 9.900 11.440	120 0.4454	13.683 0.667 5.095		Vel = 19.46	
B4			0.0 134.79						19.445		K Factor = 30.57	
110 to 111	97.67 97.67	8.00	30.12 30.12	1.5 1.682			9.000 9.000	120 0.0279	14.179 0.0 0.251		Vel = 4.35	
111 to 112	97.67 97.67	8.00	30.39 60.51	1.5 1.682			9.000 9.000	120 0.1012	14.430 0.0 0.911		Vel = 8.74	
112 to T2	97.67 97.67	8.00	31.34 91.85	1.5 1.682	L	2.475	6.790 2.475 9.265	120 0.2191	15.341 0.0 2.030		Vel = 13.26	
T2 to B2	97.67 96.71		0.0 91.85	1.5 1.682	T	9.9	0.960 9.900 10.860	120 0.2190	17.371 0.416 2.378		Vel = 13.26	
B2			0.0 91.85						20.165		K Factor = 20.45	
113 to 114	97.5 97.5	8.00	32.32 32.32	1.5 1.682			14.670 14.670	120 0.0317	16.318 0.0 0.465		Vel = 4.67	
114 to T3	97.5 97.5	8.00	32.77 65.09	1.5 1.682	L	2.475	10.810 2.475 13.285	120 0.1158	16.783 0.0 1.539		Vel = 9.40	
T3 to B3	97.5 96.71		0.0 65.09	1.5 1.682	T	9.9	0.790 9.900 10.690	120 0.1159	18.322 0.342 1.239		Vel = 9.40	
B3			0.0 65.09						19.903		K Factor = 14.59	
115 to 116	98.08 96.71	8.00	36.96 36.96	1.5 1.682	T	9.9	1.380 9.900 11.280	120 0.0407	21.346 0.593 0.459		Vel = 5.34	

# Final Calculations : Hazen-Williams

Century Fire Sprinklers, Inc.  
Lees Summit JOF

Page 6  
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
116 to B1	96.71 96.71		0.0 36.96	1.5 1.682	T 9.9	1.180 9.900 11.080	120 0.0407	22.398 0.0 0.451		Vel = 5.34	
B1			0.0 36.96					22.849		K Factor = 7.73	
100 to 101	98.25 98.25	8.00	26.00 26.0	1.5 1.682		14.670 14.670	120 0.0213	10.562 0.0 0.312		Vel = 3.75	
101 to 102	98.25 98.25	8.00	26.38 52.38	1.5 1.682		8.550 8.550	120 0.0774	10.874 0.0 0.662		Vel = 7.56	
102 to T5	98.25 98.25	8.00	27.17 79.55	1.5 1.682	T 9.9	2.260 9.900 12.160	120 0.1679	11.536 0.0 2.042		Vel = 11.49	
T5			0.0 79.55					13.578		K Factor = 21.59	
103 to 104	98.25 98.25	8.00	27.18 27.18	1.5 1.682		13.000 13.000	120 0.0230	11.545 0.0 0.299		Vel = 3.92	
104 to T5	98.25 98.25	8.00	27.53 54.71	1.5 1.682	T 9.9	10.740 9.900 20.640	120 0.0840	11.844 0.0 1.734		Vel = 7.90	
T5 to B5	98.25 96.71		79.56 134.27	1.5 1.682	T 9.9	1.540 9.900 11.440	120 0.4422	13.578 0.667 5.059		Vel = 19.39	
B5 to B4	96.71 96.71		0.0 134.27	3 3.26		8.000 8.000	120 0.0176	19.304 0.0 0.141		Vel = 5.16	
B4 to B3	96.71 96.71		134.79 269.06	3 3.26		7.180 7.180	120 0.0638	19.445 0.0 0.458		Vel = 10.34	
B3 to B2	96.71 96.71		65.09 334.15	3 3.26		2.760 2.760	120 0.0949	19.903 0.0 0.262		Vel = 12.84	
B2 to B1	96.71 96.71		91.84 425.99	3 3.26	2L 13.44	4.550 13.440 17.990	120 0.1492	20.165 0.0 2.684		Vel = 16.37	
B1 to 7	96.71 97.29		36.97 462.96	3 3.26	4L 26.879	60.500 26.879 87.379	120 0.1740	22.849 -0.251 15.203		Vel = 17.79	
7 to 6	97.29 95.5		0.0 462.96	3 3.26	3L 20.159	12.500 20.159 32.659	120 0.1740	37.801 0.775 5.683		Vel = 17.79	
6 to 5	95.5 95.5		0.0 462.96	3 3.26		43.740 43.740	120 0.1740	44.259 0.0 7.610		Vel = 17.79	
5 to 4	95.5 94.88		0.0 462.96	4 4.26	2L 15.8	4.600 15.800 20.400	120 0.0473	51.869 0.269 0.964		Vel = 10.42	

# Final Calculations : Hazen-Williams

Century Fire Sprinklers, Inc.  
Lees Summit JOF

Page 7  
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
4 to 3	94.88 94.88		0.0 462.96	4 4.26		3.280 3.280	120 0.0473	53.102 0.0 0.155		Vel = 10.42	
3 to 2	94.88 94.88		0.0 462.96	4 4.26	L 7.9	30.000 7.900 37.900	120 0.0473	53.257 0.0 1.792		Vel = 10.42	
2 to 1	94.88 95		0.0 462.96	4 4.26	3L 23.701	30.000 23.701 53.701	120 0.0473	55.049 -0.052 2.539		Vel = 10.42	
1 to BR1	95 87		0.0 462.96	4 4.26	B 15.8 S 28.968 T 26.334	10.000 71.102 81.102	120 0.0473	57.536 3.465 3.834		Vel = 10.42	
BR1 to BF	87 87		0.0 462.96	4 4.26	Zca 0.0	1.000 1.000	120 0.0470	64.835 7.341 0.047		** Fixed Loss = 7.341 Vel = 10.42	
BF to UG	87 90		0.0 462.96	4 4.26	2L 15.8	8.000 15.800 23.800	120 0.0473	72.223 -1.299 1.125		Vel = 10.42	
UG to TEST	90 100		0.0 462.96	6 6.16	4L 51.645 T 43.037 G 4.304	400.000 98.986 498.986	140 0.0059	72.049 -4.331 2.944		Vel = 4.98	
TEST			250.00 712.96					70.662		Qa = 250.00 K Factor = 84.81	





## Hydraulic Calculations by HydraCALC

Century Fire Sprinklers, Inc.  
1901 Bedford Ave,  
North Kansas City, MO 64116  
816-556-0808

Job Name : Lees Summit JOF  
Drawing : 2  
Location : 2 NE TUDOR RD - LEES SUMMIT, MO 64086  
Remote Area : 2  
Contract : KC1-1508  
Data File : Lees Summit JOF\_FS Lower EC Area 2.WXF

---

**HYDRAULIC CALCULATIONS**  
**for**

**JOB NAME** Lees Summit JOF  
**Location** 2 NE TUDOR RD - LEES SUMMIT, MO 64086  
**Drawing #** 2  
**Contract #** KC1-1508  
**Date** 05/07/2025

**DESIGN**

**Remote area #** 2  
**Remote area location** Lower Level Dispatch  
**Occupancy classification** Light  
**Density** 0.1 - Gpm/SqFt  
**Area of application** 1950 - SqFt  
**Coverage/sprinkler** 256 - SqFt  
**Type of sprinkler calculated** QR EC PEN 8.0K  
**# Sprinklers calculated** 11  
**In-rack demand** 0 - GPM  
**Hose streams** 100 - GPM  
**Total water required (including hose streams)** 424.029 - GPM @ 64.0801 - Psi  
**Type of system** Dbl Interlock- Pre Act  
**Volume of system (dry or pre-action)** 135 - Gal

**WATER SUPPLY INFORMATION**

**Test date** 08/15/2024  
**Location** NW Sloan between Main St. and NE Tudor Rd.  
**Source of info** SPEC. SECTION 211313

**CONTRACTOR INFO** Century Fire Sprinklers, Inc.  
**Address** 1901 Bedford Ave, / North Kansas City, MO 64116  
**Phone #** 816-556-0808  
**Name of designer** DJS  
**Authority having jurisdiction**  
**NOTES:**

text1(35) - invisible

# Water Supply Curve

Century Fire Sprinklers, Inc.  
Lees Summit JOF


Page 2  
Date

### City Water Supply:

C1 - Static Pressure : 85  
C2 - Residual Pressure: 62  
C2 - Residual Flow : 2100

### Demand:

D1 - Elevation : -1.949  
D2 - System Flow : 324.029  
D2 - System Pressure : 64.080  
Hose ( Demand ) : 100  
D3 - System Demand : 424.029  
Safety Margin : 19.728



# Fittings Used Summary

Century Fire Sprinklers, Inc.  
Lees Summit JOF

Page 3  
Date

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	0	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
L	NFPA 13 Long Turn Elbow	0	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zca	Colt C200 Horiz	Fitting generates a Fixed Loss Based on Flow																			

## Units Summary

Diameter Units                   Inches  
Length Units                     Feet  
Flow Units                        US Gallons per Minute  
Pressure Units                  Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Flow Summary - NFPA

Century Fire Sprinklers, Inc.  
Lees Summit JOF

Page 4  
Date

## SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	85.0	62	2100.0	83.808	424.03	64.08

## NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
204	96.17	8	10.87	26.38	0.1 256
205	96.17	8	12.33	28.09	0.1 256
206	95.5	8	10.84	26.33	0.1 256
207	96.58		12.85		
208	96.58		13.27		
209	96.58		15.05		
210	96.17	8	11.12	26.67	0.1 256
211	96.17	8	12.61	28.4	0.1 256
212	95.5	8	12.96	28.8	0.1 256
213	96.58		15.32		
214	96.58		15.9		
215	96.58		18.0		
216	95.5	8	13.43	29.32	0.1 256
217	95.5	8	15.19	31.18	0.1 256
218	96.17	8	18.99	34.86	0.1 256
219	97.17		22.57		
22	97.17		23.47		
220	95.5	8	22.5	37.95	0.1 256
200	95.5	8	10.6	26.05	0.1 256
201	96.58		12.56		
202	96.58		12.98		
203	96.58		14.72		
21	96.58		19.61		
20	96.58		20.04		
19	96.58		21.58		
18	96.58		22.63		
17	95.88		23.09		
16	95.88		24.46		
15	95.88		26.86		
14	95.88		30.7		
13	95.88		36.8		
12	95.5		43.67		
11	94.67		45.95		
10	94.67		53.08		
BR2	87.0		63.09		
BF	87.0		67.61		
UG	90.0		66.89		
TEST	100.0		64.08	100.0	

# Final Calculations : Hazen-Williams

Century Fire Sprinklers, Inc.  
Lees Summit JOF

Page 5  
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
204 to 202	96.17 96.58	8.00	26.38 26.38	1 1.049	2E T	2.855 3.568	1.090 6.423 7.513	100 0.3043	10.871 -0.178 2.286		Vel = 9.79	
202			0.0 26.38						12.979		K Factor = 7.32	
205 to 203	96.17 96.58	8.00	28.09 28.09	1 1.049	2E T	2.855 3.568	1.090 6.423 7.513	100 0.3418	12.329 -0.178 2.568		Vel = 10.43	
203			0.0 28.09						14.719		K Factor = 7.32	
206 to 207	95.5 96.58	8.00	26.33 26.33	1 1.049	2E T	2.855 3.568	1.750 6.423 8.173	100 0.3034	10.836 -0.468 2.480		Vel = 9.77	
207 to 208	96.58 96.58		0.0 26.33	1.5 1.682			14.000 14.000	100 0.0304	12.848 0.0 0.426		Vel = 3.80	
208 to 209	96.58 96.58		26.68 53.01	1.5 1.682			16.000 16.000	100 0.1110	13.274 0.0 1.776		Vel = 7.65	
209 to 20	96.58 96.58		28.40 81.41	1.5 1.682	T	7.065	13.250 7.066 20.316	100 0.2456	15.050 0.0 4.989		Vel = 11.75	
20			0.0 81.41						20.039		K Factor = 18.19	
210 to 208	96.17 96.58	8.00	26.67 26.67	1 1.049	2E T	2.855 3.568	1.090 6.423 7.513	100 0.3107	11.118 -0.178 2.334		Vel = 9.90	
208			0.0 26.67						13.274		K Factor = 7.32	
211 to 209	96.17 96.58	8.00	28.40 28.4	1 1.049	2E T	2.855 3.568	1.090 6.423 7.513	100 0.3490	12.606 -0.178 2.622		Vel = 10.54	
209			0.0 28.40						15.050		K Factor = 7.32	
212 to 213	95.5 96.58	8.00	28.80 28.8	1 1.049	T 2E	3.568 2.855	1.500 6.423 7.923	100 0.3579	12.956 -0.468 2.836		Vel = 10.69	
213 to 214	96.58 96.58		0.0 28.8	1.5 1.682			16.000 16.000	100 0.0359	15.324 0.0 0.575		Vel = 4.16	
214 to 215	96.58 96.58		29.32 58.12	1.5 1.682			16.000 16.000	100 0.1316	15.899 0.0 2.106		Vel = 8.39	
215 to 19	96.58 96.58		31.18 89.3	1.5 1.682	T	7.065	5.210 7.066 12.276	100 0.2913	18.005 0.0 3.576		Vel = 12.89	
19			0.0 89.30						21.581		K Factor = 19.22	

# Final Calculations : Hazen-Williams

Century Fire Sprinklers, Inc.  
Lees Summit JOF

Page 6  
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
216 to 214	95.5 96.58	8.00	29.32 29.32	1 1.049	T 2E	3.568 2.855	1.500 6.423	100 -0.468			
			0.0				7.923	2.933	Vel = 10.88		
214			29.32					15.899	K Factor = 7.35		
217 to 215	95.5 96.58	8.00	31.18 31.18	1 1.049	T 2E	3.568 2.855	1.500 6.423	100 -0.468			
			0.0				7.923	3.285	Vel = 11.57		
215			31.18					18.005	K Factor = 7.35		
218 to 219	96.17 97.17	8.00	34.86 34.86	1 1.049	2E T	2.855 3.568	1.460 6.423	100 -0.433			
			0.0				7.883	4.018	Vel = 12.94		
219 to 22	97.17 97.17		0.0 34.86	1.5 1.682	L	1.766	15.790 1.766	100 0.0			
			0.0				17.556	0.897	Vel = 5.03		
22 to 16	97.17 95.88		0.0 34.86	1.5 1.682	T	7.065	1.290 7.066	100 0.559			
			0.0				8.356	0.427	Vel = 5.03		
16			34.86					24.455	K Factor = 7.05		
220 to 15	95.5 95.88	8.00	37.95 37.95	1 1.049	2E T	2.855 3.568	1.170 6.423	100 -0.165			
			0.0				7.593	4.528	Vel = 14.09		
15			37.95					26.864	K Factor = 7.32		
200 to 201	95.5 96.58	8.00	26.05 26.05	1 1.049	2E T	2.855 3.568	1.750 6.423	100 -0.468			
			0.0				8.173	2.430	Vel = 9.67		
201 to 202	96.58 96.58		0.0 26.05	1.5 1.682			14.000 14.000	100 0.0			
			26.05				14.000	0.417	Vel = 3.76		
202 to 203	96.58 96.58		26.37 52.42	1.5 1.682			16.000 16.000	100 0.0			
			26.37				16.000	1.740	Vel = 7.57		
203 to 21	96.58 96.58		28.09 80.51	1.5 1.682	T	7.065	13.250 7.066	100 0.0			
			0.0				20.316	4.887	Vel = 11.62		
21 to 20	96.58 96.58		0.0 80.51	2.5 2.635			16.000 16.000	100 0.0			
			80.51				16.000	0.433	Vel = 4.74		
20 to 19	96.58 96.58		81.42 161.93	2.5 2.635			15.670 15.670	100 0.0			
			161.93				15.670	1.542	Vel = 9.53		
19 to 18	96.58 96.58		89.29 251.22	2.5 2.635	L	3.919	0.790 3.919	100 0.0			
			251.22				4.709	1.045	Vel = 14.78		

# Final Calculations : Hazen-Williams

Century Fire Sprinklers, Inc.  
Lees Summit JOF

Page 7  
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
18 to 17	96.58 95.88		0.0 251.22	2.5 2.635		0.710 0.710	100 0.2211	22.626 0.303 0.157		Vel = 14.78	
17 to 16	95.88 95.88		0.0 251.22	2.5 2.635	L 3.919	2.250 3.919 6.169	100 0.2219	23.086 0.0 1.369		Vel = 14.78	
16 to 15	95.88 95.88		34.86 286.08	2.5 2.635		8.540 8.540	100 0.2821	24.455 0.0 2.409		Vel = 16.83	
15 to 14	95.88 95.88		37.95 324.03	2.5 2.635	L 3.919	6.890 3.919 10.809	100 0.3553	26.864 0.0 3.840		Vel = 19.06	
14 to 13	95.88 95.88		0.0 324.03	3 3.26		48.390 48.390	100 0.1260	30.704 0.0 6.097		Vel = 12.45	
13 to 12	95.88 95.5		0.0 324.03	3 3.26	4L T 19.184 14.388	19.670 33.571 53.241	100 0.1260	36.801 0.165 6.708		Vel = 12.45	
12 to 11	95.5 94.67		0.0 324.03	3 3.26	T 14.388	0.830 14.387 15.217	100 0.1260	43.674 0.359 1.917		Vel = 12.45	
11 to 10	94.67 94.67		0.0 324.03	3 3.26	2L 9.592	47.000 9.592 56.592	100 0.1260	45.950 0.0 7.131		Vel = 12.45	
10 to BR2	94.67 87		0.0 324.03	3 3.26	B S 15.347 20.143	8.000 45.082 53.082	100 0.1260	53.081 3.322 6.687		Vel = 12.45	
BR2 to BF	87 87		0.0 324.03	4 4.26	Zca 0.0	1.000 1.000	120 0.0250	63.090 4.493 0.025		** Fixed Loss = 4.493 Vel = 7.29	
BF to UG	87 90		0.0 324.03	4 4.26	2L 15.8	8.000 15.800 23.800	120 0.0244	67.608 -1.299 0.581		Vel = 7.29	
UG to TEST	90 100		0.0 324.03	6 6.16	4L T 51.645 43.037 4.304	400.000 98.986 498.986	140 0.0030	66.890 -4.331 1.521		Vel = 3.49	
TEST			100.00 424.03					64.080		Qa = 100.00 K Factor = 52.97	





## Hydraulic Calculations by HydraCALC

Century Fire Sprinklers, Inc.  
1901 Bedford Ave,  
North Kansas City, MO 64116  
816-556-0808

Job Name : Lees Summit JOF  
Drawing : 2  
Location : 2 NE TUDOR RD - LEES SUMMIT, MO 64086  
Remote Area : 3  
Contract : KC1-1508  
Data File : Lees Summit JOF\_FS Main Level-CALC Area 3.WXF

---

**HYDRAULIC CALCULATIONS**  
**for**

**JOB NAME** Lees Summit JOF  
**Location** 2 NE TUDOR RD - LEES SUMMIT, MO 64086  
**Drawing #** 2  
**Contract #** KC1-1508  
**Date** 05/07/2025

**DESIGN**

**Remote area #** 3  
**Remote area location** Mian Level - North  
**Occupancy classification** Light  
**Density** 0.1 - Gpm/SqFt  
**Area of application** 1500 - SqFt  
**Coverage/sprinkler** 180 - SqFt  
**Type of sprinkler calculated** QR PEN 5.6K  
**# Sprinklers calculated** 13  
**In-rack demand** 0 - GPM  
**Hose streams** 100 - GPM  
**Total water required (including hose streams)** 375.796 - GPM @ 62.9899 - Psi  
**Type of system** WET  
**Volume of system (dry or pre-action)** 0 - Gal

**WATER SUPPLY INFORMATION**

**Test date** 08/15/2024  
**Location** NW Sloan between Main St. and NE Tudor Rd.  
**Source of info** SPEC. SECTION 211313

**CONTRACTOR INFO** Century Fire Sprinklers, Inc.  
**Address** 1901 Bedford Ave, / North Kansas City, MO 64116  
**Phone #** 816-556-0808  
**Name of designer** DJS  
**Authority having jurisdiction**

**NOTES:**

text1(35) - invisible


# Water Supply Curve

Century Fire Sprinklers, Inc.  
Lees Summit JOF

Page 2  
Date

City Water Supply:  
C1 - Static Pressure : 85  
C2 - Residual Pressure: 62  
C2 - Residual Flow : 2100

Demand:  
D1 - Elevation : 4.907  
D2 - System Flow : 275.796  
D2 - System Pressure : 62.990  
Hose ( Demand ) : 100  
D3 - System Demand : 375.796  
Safety Margin : 21.057



# Fittings Used Summary

Century Fire Sprinklers, Inc.  
Lees Summit JOF

Page 3  
Date

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	0	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
L	NFPA 13 Long Turn Elbow	0	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zca	Colt C200 Horiz	Fitting generates a Fixed Loss Based on Flow																			

## Units Summary

Diameter Units                   Inches  
 Length Units                    Feet  
 Flow Units                       US Gallons per Minute  
 Pressure Units                 Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Flow Summary - NFPA

Century Fire Sprinklers, Inc.  
Lees Summit JOF

Page 4  
Date

## SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	85.0	62	2100.0	84.047	375.8	62.99

## NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
307	111.33	5.6	10.49	18.13	0.1 180
308	111.33	5.6	10.94	18.52	0.1 180
309	111.33	5.6	10.94	18.52	0.15 100
310	111.33	5.6	12.81	20.04	0.1 180
311	111.33	5.6	16.35	22.64	0.1 180
312	111.33	5.6	13.03	20.22	0.1 180
313	111.33		19.54		
314	111.33		20.34		
315	111.33		23.41		
316	111.33		28.07		
317	110.67	5.6	13.78	20.79	0.1 180
318	111.33	5.6	13.12	20.28	0.1 180
319	111.33		19.26		
320	111.33	5.6	15.69	22.18	0.1 180
321	111.33	5.6	18.9	24.35	0.1 180
322	111.33	5.6	21.47	25.95	0.1 180
323	111.33		31.79		
324	111.33		32.33		
325	111.33	5.6	21.84	26.17	0.1 180
300	111.33	5.6	10.33	18.0	0.1 180
301	111.33		15.58		
302	111.33		15.81		
303	111.33		16.47		
304	111.33		19.21		
305	111.33		24.37		
36	111.33		32.93		
35	111.33		33.07		
34	111.33		33.17		
33	111.33		33.63		
32	111.33		35.82		
31	111.33		39.63		
30	111.33		40.93		
7	97.29		49.94		
6	95.5		52.89		
5	95.5		55.81		
4	94.88		56.45		
3	94.88		56.51		
2	94.88		57.2		
1	95.0		58.12		
BR1	87.0		63.06		
BF	87.0		67.06		
UG	90.0		66.19		

# Flow Summary - NFPA

Century Fire Sprinklers, Inc.  
Lees Summit JOF

Page 5  
Date

---

## *NODE ANALYSIS (cont.)*

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
TEST	100.0		62.99	100.0	

# Final Calculations : Hazen-Williams

Century Fire Sprinklers, Inc.  
Lees Summit JOF

Page 6  
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
307 to 302	111.33 111.33	5.60	18.13 18.13	1 1.049	T	5.0	44.000 5.000 49.000	120	10.486 0.0 5.320		Vel = 6.73	
302			0.0 18.13						15.806		K Factor = 4.56	
308 to 303	111.33 111.33	5.60	18.52 18.52	1 1.049	T	5.0	44.000 5.000 49.000	120	10.938 0.0 5.532		Vel = 6.88	
303			0.0 18.52						16.470		K Factor = 4.56	
309 to 303	111.330 111.33	5.60	18.52 18.52	1 1.049	T	5.0	44.000 5.000 49.000	120	10.938 0.0 5.532		Vel = 6.88	
303			0.0 18.52						16.470		K Factor = 4.56	
310 to 304	111.330 111.33	5.60	20.04 20.04	1 1.049	T	5.0	44.000 5.000 49.000	120	12.809 0.0 6.401		Vel = 7.44	
304			0.0 20.04						19.210		K Factor = 4.57	
311 to 305	111.33 111.33	5.60	22.64 22.64	1 1.049	T	5.0	44.000 5.000 49.000	120	16.349 0.0 8.022		Vel = 8.40	
305			0.0 22.64						24.371		K Factor = 4.59	
312 to 313	111.33 111.33	5.60	20.22 20.22	1 1.049	T	5.0	44.000 5.000 49.000	120	13.035 0.0 6.506		Vel = 7.51	
313 to 314	111.33 111.33		20.28 40.5	1.25 1.442			7.870 7.870	120	19.541 0.0 0.802		Vel = 7.96	
314 to 315	111.33 111.33		20.79 61.29	1.25 1.442			14.000 14.000	120	20.343 0.0 3.071		Vel = 12.04	
315 to 316	111.33 111.33		22.18 83.47	1.25 1.442			12.000 12.000	120	23.414 0.0 4.661		Vel = 16.40	
316 to 35	111.33 111.33		24.35 107.82	1.25 1.442	T	7.432	0.570 7.432 8.002	120	28.075 0.0 4.991		Vel = 21.18	
35			0.0 107.82						33.066		K Factor = 18.75	
317 to 314	110.67 111.33	5.60	20.79 20.79	1 1.049	T	5.0	44.000 5.000 49.000	120	13.780 -0.286 6.849		Vel = 7.72	
314			0.0 20.79						20.343		K Factor = 4.61	

# Final Calculations : Hazen-Williams

Century Fire Sprinklers, Inc.  
Lees Summit JOF

Page 7  
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
318 to 319	111.33 111.33	5.60	20.28 20.28	1 1.049	E 2.0	44.000 2.000 46.000	120 0.1335	13.117 0.0 6.143		Vel = 7.53	
319 to 313	111.33 111.33		0.0 20.28	1.25 1.38		8.000 8.000	120 0.0351	19.260 0.0 0.281		Vel = 4.35	
313			0.0 20.28					19.541		K Factor = 4.59	
320 to 315	111.33 111.33	5.60	22.18 22.18	1 1.049	T 5.0	44.000 5.000 49.000	120 0.1576	15.691 0.0 7.723		Vel = 8.23	
315			0.0 22.18					23.414		K Factor = 4.58	
321 to 316	111.33 111.33	5.60	24.35 24.35	1 1.049	T 5.0	44.000 5.000 49.000	120 0.1872	18.901 0.0 9.174		Vel = 9.04	
316			0.0 24.35					28.075		K Factor = 4.60	
322 to 323	111.33 111.33	5.60	25.95 25.95	1 1.049	T 5.0	44.000 5.000 49.000	120 0.2107	21.470 0.0 10.322		Vel = 9.63	
323 to 324	111.33 111.33		0.0 25.95	1.25 1.442		12.000 12.000	120 0.0447	31.792 0.0 0.536		Vel = 5.10	
324 to 33	111.33 111.33		26.17 52.12	1.25 1.442	T 7.432	0.570 7.432 8.002	120 0.1626	32.328 0.0 1.301		Vel = 10.24	
33			0.0 52.12					33.629		K Factor = 8.99	
325 to 324	111.33 111.33	5.60	26.17 26.17	1 1.049	T 5.0	44.000 5.000 49.000	120 0.2140	21.841 0.0 10.487		Vel = 9.71	
324			0.0 26.17					32.328		K Factor = 4.60	
300 to 301	111.33 111.33	5.60	18.00 18.0	1 1.049	T 5.0	44.000 5.000 49.000	120 0.1071	10.332 0.0 5.247		Vel = 6.68	
301 to 302	111.33 111.33		0.0 18.0	1.25 1.442		10.000 10.000	120 0.0227	15.579 0.0 0.227		Vel = 3.54	
302 to 303	111.33 111.33		18.13 36.13	1.25 1.442		8.040 8.040	120 0.0826	15.806 0.0 0.664		Vel = 7.10	
303 to 304	111.33 111.33		37.05 73.18	1.25 1.442		9.000 9.000	120 0.3044	16.470 0.0 2.740		Vel = 14.38	
304 to 305	111.33 111.33		20.04 93.22	1.25 1.442		10.830 10.830	120 0.4765	19.210 0.0 5.161		Vel = 18.31	



# Final Calculations : Hazen-Williams

Century Fire Sprinklers, Inc.  
Lees Summit JOF

Page 8  
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
305 to 36	111.33 111.33		22.64 115.86	1.25 1.442	T	7.432	4.580 7.432 12.012	120	24.371 0.0 8.558			Vel = 22.76
36 to 35	111.33 111.33		0.0 115.86	3 3.26			10.170 10.170	120	32.929 0.0 0.137			Vel = 4.45
35 to 34	111.33 111.33		107.82 223.68	3 3.26			2.270 2.270	120	33.066 0.0 0.102			Vel = 8.60
34 to 33	111.33 111.33		0.0 223.68	3 3.26			10.170 10.170	120	33.168 0.0 0.461			Vel = 8.60
33 to 32	111.33 111.33		52.12 275.8	3 3.26	T	20.159	12.620 20.159 32.779	120	33.629 0.0 2.188			Vel = 10.60
32 to 31	111.33 111.33		0.0 275.8	3 3.26	T	20.159	37.000 20.159 57.159	120	35.817 0.0 3.814			Vel = 10.60
31 to 30	111.33 111.33		0.0 275.8	3 3.26	L	6.72	12.750 6.720 19.470	120	39.631 0.0 1.300			Vel = 10.60
30 to 7	111.33 97.29		0.0 275.8	3 3.26	L T	6.72 20.159	17.000 26.879 43.879	120	40.931 6.081 2.928			Vel = 10.60
7			0.0 275.80						49.940			K Factor = 39.03
7 to 6	97.29 95.5		275.80 275.8	3 3.26	3L	20.159	12.500 20.159 32.659	120	49.940 0.775 2.180			Vel = 10.60
6 to 5	95.5 95.5		0.0 275.8	3 3.26			43.740 43.740	120	52.895 0.0 2.919			Vel = 10.60
5 to 4	95.5 94.88		0.0 275.8	4 4.26	2L	15.8	4.600 15.800 20.400	120	55.814 0.269 0.369			Vel = 6.21
4 to 3	94.88 94.88		0.0 275.8	4 4.26			3.280 3.280	120	56.452 0.0 0.060			Vel = 6.21
3 to 2	94.88 94.88		0.0 275.8	4 4.26	L	7.9	30.000 7.900 37.900	120	56.512 0.0 0.687			Vel = 6.21
2 to 1	94.88 95		0.0 275.8	4 4.26	3L	23.701	30.000 23.701 53.701	120	57.199 -0.052 0.974			Vel = 6.21
1 to BR1	95 87		0.0 275.8	4 4.26	B S T	15.8 28.968 26.334	10.000 71.102 81.102	120	58.121 3.465 1.470			Vel = 6.21
BR1 to BF	87 87		0.0 275.8	4 4.26	Zca	0.0	1.000 1.000	120	63.056 3.985 0.019			* * Fixed Loss = 3.985 Vel = 6.21

# Final Calculations : Hazen-Williams

Century Fire Sprinklers, Inc.  
Lees Summit JOF

Page 9  
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
BF to UG	87 90		0.0 275.8	4 4.26	2L	15.8	8.000 15.800 23.800	120 0.0181	67.060 -1.299 0.431		Vel = 6.21	
UG to TEST	90 100		0.0 275.8	6 6.16	4L T G	51.645 43.037 4.304	400.000 98.986 498.986	140 0.0023	66.192 -4.331 1.129		Vel = 2.97	
TEST			100.00 375.80						62.990		Qa = 100.00 K Factor = 47.35	



## Hydraulic Calculations by HydraCALC

Century Fire Sprinklers, Inc.  
1901 Bedford Ave,  
North Kansas City, MO 64116  
816-556-0808

Job Name : Lees Summit JOF  
Drawing : 2  
Location : 2 NE TUDOR RD - LEES SUMMIT, MO 64086  
Remote Area : 4  
Contract : KC1-1508  
Data File : Lees Summit JOF\_FS Main Level-CALC Area 4.WXF

---

**HYDRAULIC CALCULATIONS**  
**for**

**JOB NAME** Lees Summit JOF  
**Location** 2 NE TUDOR RD - LEES SUMMIT, MO 64086  
**Drawing #** 2  
**Contract #** KC1-1508  
**Date** 05/07/2025

**DESIGN**

**Remote area #** 4  
**Remote area location** Lobby  
**Occupancy classification** Light  
**Density** 0.1 - Gpm/SqFt  
**Area of application** 1500 - SqFt  
**Coverage/sprinkler** 196 - SqFt  
**Type of sprinkler calculated** QR PEN 5.6K  
**# Sprinklers calculated** 11  
**In-rack demand** 0 - GPM  
**Hose streams** 100 - GPM  
**Total water required (including hose streams)** 337.268 - GPM @ 66.087 - Psi  
**Type of system** WET  
**Volume of system (dry or pre-action)** 0 - Gal

**WATER SUPPLY INFORMATION**

**Test date** 08/15/2024  
**Location** NW Sloan between Main St. and NE Tudor Rd.  
**Source of info** SPEC. SECTION 211313

**CONTRACTOR INFO** Century Fire Sprinklers, Inc.  
**Address** 1901 Bedford Ave, / North Kansas City, MO 64116  
**Phone #** 816-556-0808  
**Name of designer** DJS  
**Authority having jurisdiction**  
**NOTES:**

text1(35) - invisible

# Water Supply Curve

Century Fire Sprinklers, Inc.  
Lees Summit JOF


Page 2  
Date

## City Water Supply:

C1 - Static Pressure : 85  
C2 - Residual Pressure: 62  
C2 - Residual Flow : 2100

## Demand:

D1 - Elevation : 10.143  
D2 - System Flow : 237.268  
D2 - System Pressure : 66.087  
Hose ( Demand ) : 100  
D3 - System Demand : 337.268  
Safety Margin : 18.132



# Fittings Used Summary

Century Fire Sprinklers, Inc.  
Lees Summit JOF

Page 3  
Date

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	0	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
L	NFPA 13 Long Turn Elbow	0	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zca	Colt C200 Horiz	Fitting generates a Fixed Loss Based on Flow																			

## Units Summary

Diameter Units                   Inches  
Length Units                       Feet  
Flow Units                         US Gallons per Minute  
Pressure Units                   Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Flow Summary - NFPA

Century Fire Sprinklers, Inc.  
Lees Summit JOF

Page 4  
Date

## SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	85.0	62	2100.0	84.219	337.27	66.087

## NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
405	123.42	5.6	12.29	19.63	0.1 196
406	124.0		17.82		
407	123.42	5.6	13.04	20.22	0.1 196
408	123.42	5.6	15.89	22.32	0.1 196
409	123.42	5.6	12.89	20.11	0.1 196
410	124.0		19.08		
411	124.0		20.29		
412	124.0		22.81		
44	124.0		28.42		
413	123.42	5.6	12.88	20.1	0.1 196
414	124.0		18.67		
415	123.42	5.6	13.72	20.74	0.1 196
416	123.42	5.6	15.45	22.01	0.1 196
417	123.42	5.6	17.97	23.74	0.1 196
418	124.0		26.48		
419	124.0		27.01		
420	123.42	5.6	18.34	23.98	0.1 196
421	123.42	5.6	19.63	24.81	0.1 196
422	124.0		28.88		
400	123.42	5.6	12.25	19.6	0.1 196
401	124.0		18.14		
402	124.0		19.29		
403	124.0		23.45		
43	124.0		28.92		
42	124.0		29.33		
41	124.0		32.03		
40	111.33		42.78		
31	111.33		46.27		
30	111.33		47.25		
7	97.29		55.55		
6	95.5		57.97		
5	95.5		60.18		
4	94.88		60.73		
3	94.88		60.78		
2	94.88		61.3		
1	95.0		61.98		
BR1	87.0		66.56		
BF	87.0		70.54		
UG	90.0		69.56		
TEST	100.0		66.09	100.0	

# Final Calculations : Hazen-Williams

Century Fire Sprinklers, Inc.  
Lees Summit JOF

Page 5  
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
405 to 406	123.42 124	5.60	19.63 19.63	1 1.049	E 2.0	44.000 2.000 46.000	120 0.1257	12.289 -0.251 5.783		Vel = 7.29	
406 to 401	124 124		0.0 19.63	1.25 1.442		12.000 12.000	120 0.0267	17.821 0.0 0.320		Vel = 3.86	
401			0.0 19.63					18.141		K Factor = 4.61	
407 to 402	123.42 124	5.60	20.22 20.22	1 1.049	T 5.0	44.000 5.000 49.000	120 0.1328	13.038 -0.251 6.507		Vel = 7.51	
402			0.0 20.22					19.294		K Factor = 4.60	
408 to 403	123.42 124	5.60	22.32 22.32	1 1.049	T 5.0	44.000 5.000 49.000	120 0.1595	15.890 -0.251 7.814		Vel = 8.29	
403			0.0 22.32					23.453		K Factor = 4.61	
409 to 410	123.42 124	5.60	20.11 20.11	1 1.049	T 5.0	44.000 5.000 49.000	120 0.1314	12.894 -0.251 6.441		Vel = 7.47	
410 to 411	124 124		20.10 40.21	1.25 1.442		12.000 12.000	120 0.1006	19.084 0.0 1.207		Vel = 7.90	
411 to 412	124 124		20.74 60.95	1.25 1.442		11.600 11.600	120 0.2171	20.291 0.0 2.518		Vel = 11.97	
412 to 44	124 124		22.01 82.96	1.25 1.442	T 7.432	7.190 7.432 14.622	120 0.3841	22.809 0.0 5.616		Vel = 16.30	
44 to 43	124 124		47.72 130.68	2.5 2.635		10.500 10.500	120 0.0472	28.425 0.0 0.496		Vel = 7.69	
43			0.0 130.68					28.921		K Factor = 24.30	
413 to 414	123.42 124	5.60	20.10 20.1	1 1.049	E 2.0	44.000 2.000 46.000	120 0.1313	12.880 -0.251 6.040		Vel = 7.46	
414 to 410	124 124		0.0 20.1	1.25 1.38		12.000 12.000	120 0.0346	18.669 0.0 0.415		Vel = 4.31	
410			0.0 20.10					19.084		K Factor = 4.60	
415 to 411	123.42 124	5.60	20.74 20.74	1 1.049	T 5.0	44.000 5.000 49.000	120 0.1392	13.720 -0.251 6.822		Vel = 7.70	
411			0.0 20.74					20.291		K Factor = 4.60	



# Final Calculations : Hazen-Williams

Century Fire Sprinklers, Inc.  
Lees Summit JOF

Page 6  
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
416 to 412	123.42 124	5.60	22.01 22.01	1 1.049	T	5.0	44.000 5.000 49.000	120	15.448 -0.251 7.612			Vel = 8.17
412			0.0 22.01						22.809		K Factor = 4.61	
417 to 418	123.42 124	5.60	23.74 23.74	1 1.049	T	5.0	44.000 5.000 49.000	120	17.974 -0.251 8.756			Vel = 8.81
418 to 419	124 124		0.0 23.74	1.25 1.442			14.000 14.000	120	26.479 0.0 0.532			Vel = 4.66
419 to 44	124 124		23.98 47.72	1.25 1.442	T	7.432	2.810 7.432 10.242	120	27.011 0.0 1.414			Vel = 9.37
44			0.0 47.72						28.425		K Factor = 8.95	
420 to 419	123.42 124	5.60	23.98 23.98	1 1.049	T	5.0	44.000 5.000 49.000	120	18.340 -0.251 8.922			Vel = 8.90
419			0.0 23.98						27.011		K Factor = 4.61	
421 to 422	123.42 124	5.60	24.81 24.81	1 1.049	T	5.0	44.000 5.000 49.000	120	19.629 -0.251 9.500			Vel = 9.21
422 to 42	124 124		0.0 24.81	1.25 1.38	T	6.0	2.810 6.000 8.810	120	28.878 0.0 0.450			Vel = 5.32
42			0.0 24.81						29.328		K Factor = 4.58	
400 to 401	123.42 124	5.60	19.60 19.6	1 1.049	T	5.0	44.000 5.000 49.000	120	12.250 -0.251 6.142			Vel = 7.28
401 to 402	124 124		19.63 39.23	1.25 1.442			12.000 12.000	120	18.141 0.0 1.153			Vel = 7.71
402 to 403	124 124		20.22 59.45	1.25 1.442	2L	4.955	15.100 4.955 20.055	120	19.294 0.0 4.159			Vel = 11.68
403 to 43	124 124		22.32 81.77	1.25 1.442	T	7.432	7.190 7.432 14.622	120	23.453 0.0 5.468			Vel = 16.06
43 to 42	124 124		130.69 212.46	2.5 2.635			3.500 3.500	120	28.921 0.0 0.407			Vel = 12.50
42 to 41	124 124		24.81 237.27	2.5 2.635	2L	10.983	7.980 10.983 18.963	120	29.328 0.0 2.701			Vel = 13.96

# Final Calculations : Hazen-Williams

Century Fire Sprinklers, Inc.  
Lees Summit JOF

Page 7  
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
41 to 40	124 111.33		0.0 237.27	2.5 2.635	L T	5.491 16.474	15.000 21.965 36.965	120 0.1425	32.029 5.487 5.266		Vel = 13.96	
40 to 31	111.33 111.33		0.0 237.27	2.5 2.635	T	16.474	8.000 16.474 24.474	120 0.1424	42.782 0.0 3.486		Vel = 13.96	
31 to 30	111.33 111.33		0.0 237.27	3 3.26	L	6.72	12.750 6.720 19.470	120 0.0505	46.268 0.0 0.983		Vel = 9.12	
30 to 7	111.33 97.29		0.0 237.27	3 3.26	L T	6.72 20.159	17.000 26.879 43.879	120 0.0505	47.251 6.081 2.217		Vel = 9.12	
7			0.0 237.27						55.549		K Factor = 31.83	
7 to 6	97.29 95.5		237.27	3 3.26	3L	20.159	12.500 20.159 32.659	120 0.0505	55.549 0.775 1.650		Vel = 9.12	
6 to 5	95.5 95.5		0.0 237.27	3 3.26			43.740 43.740	120 0.0505	57.974 0.0 2.210		Vel = 9.12	
5 to 4	95.5 94.88		0.0 237.27	4 4.26	2L	15.8	4.600 15.800 20.400	120 0.0137	60.184 0.269 0.279		Vel = 5.34	
4 to 3	94.88 94.88		0.0 237.27	4 4.26			3.280 3.280	120 0.0140	60.732 0.0 0.046		Vel = 5.34	
3 to 2	94.88 94.88		0.0 237.27	4 4.26	L	7.9	30.000 7.900 37.900	120 0.0137	60.778 0.0 0.520		Vel = 5.34	
2 to 1	94.88 95		0.0 237.27	4 4.26	3L	23.701	30.000 23.701 53.701	120 0.0137	61.298 -0.052 0.737		Vel = 5.34	
1 to BR1	95 87		0.0 237.27	4 4.26	B S T	15.8 28.968 26.334	10.000 71.102 81.102	120 0.0137	61.983 3.465 1.113		Vel = 5.34	
BR1 to BF	87 87		0.0 237.27	4 4.26	Zca	0.0	1.000 1.000	120 0.0140	66.561 3.961 0.014		** Fixed Loss = 3.961 Vel = 5.34	
BF to UG	87 90		0.0 237.27	4 4.26	2L	15.8	8.000 15.800 23.800	120 0.0137	70.536 -1.299 0.326		Vel = 5.34	
UG to TEST	90 100		0.0 237.27	6 6.16	4L T G	51.645 43.037 4.304	400.000 98.986 498.986	140 0.0017	69.563 -4.331 0.855		Vel = 2.55	
TEST			100.00 337.27						66.087		Qa = 100.00 K Factor = 41.49	



## Hydraulic Calculations by HydraCALC

Century Fire Sprinklers, Inc.  
1901 Bedford Ave,  
North Kansas City, MO 64116  
816-556-0808

Job Name : Lees Summit JOF\_FS  
Drawing : 2  
Location : 2 NE TUDOR RD - LEES SUMMIT, MO 64086  
Remote Area : 5  
Contract : KC1-1508  
Data File : Lees Summit JOF\_FS Main Level-CALC Area 5.WXF

---

**HYDRAULIC CALCULATIONS**  
**for**

**JOB NAME** Lees Summit JOF  
**Location** 2 NE TUDOR RD - LEES SUMMIT, MO 64086  
**Drawing #** 2  
**Contract #** KC1-1508  
**Date** 05/07/2025

**DESIGN**

**Remote area #** 5  
**Remote area location** Mian Level - South Mech  
**Occupancy classification** O.H. 1  
**Density** 0.15 - Gpm/SqFt  
**Area of application** 1500 - SqFt  
**Coverage/sprinkler** 100 - SqFt  
**Type of sprinkler calculated** QR PEN 5.6K  
**# Sprinklers calculated** 20  
**In-rack demand** 0 - GPM  
**Hose streams** 250 - GPM  
**Total water required (including hose streams)** 614.97 - GPM @ 61.1568 - Psi  
**Type of system** WET  
**Volume of system (dry or pre-action)** 0 - Gal

**WATER SUPPLY INFORMATION**

**Test date** 08/15/2024  
**Location** NW Sloan between Main St. and NE Tudor Rd.  
**Source of info** SPEC. SECTION 211313

**CONTRACTOR INFO** Century Fire Sprinklers, Inc.  
**Address** 1901 Bedford Ave, / North Kansas City, MO 64116  
**Phone #** 816-556-0808  
**Name of designer** DJS  
**Authority having jurisdiction**  
**NOTES:**

text1(35) - invisible

# Water Supply Curve

Century Fire Sprinklers, Inc.  
Lees Summit JOF\_FS


Page 2  
Date

## City Water Supply:

C1 - Static Pressure : 85  
C2 - Residual Pressure: 62  
C2 - Residual Flow : 2100

## Demand:

D1 - Elevation : 4.188  
D2 - System Flow : 364.97  
D2 - System Pressure : 61.157  
Hose ( Demand ) : 250  
D3 - System Demand : 614.97  
Safety Margin : 21.472



# Fittings Used Summary

Century Fire Sprinklers, Inc.  
Lees Summit JOF\_FS

Page 3  
Date

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	0	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
L	NFPA 13 Long Turn Elbow	0	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zca	Colt C200 Horiz	Fitting generates a Fixed Loss Based on Flow																			

## Units Summary

Diameter Units                   Inches  
Length Units                       Feet  
Flow Units                         US Gallons per Minute  
Pressure Units                   Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Flow Summary - NFPA

Century Fire Sprinklers, Inc.  
Lees Summit JOF\_FS

Page 4  
Date

## SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	85.0	62	2100.0	82.629	614.97	61.157

## NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>		<i>Notes</i>
505	109.67	5.6	12.47	19.77	0.1	196
506	109.67	5.6	13.13	20.29	0.1	196
507	109.67	5.6	15.13	21.78	0.1	196
508	113.21	5.6	8.58	16.41	0.15	100
509	113.21	5.6	8.62	16.44	0.15	100
69	113.21		8.87			
64	112.08		9.96			
63	112.08		10.0			
62	112.08		10.17			
61	112.58		10.34			
60	112.58		11.31			
59	112.58		12.11			
58	112.58		15.62			
57	112.58		18.48			
56	110.5		23.3			
510	113.21	5.6	8.65	16.47	0.15	100
511	113.21	5.6	8.63	16.45	0.15	100
68	113.21		8.91			
512	113.21	5.6	8.8	16.62	0.15	100
513	113.21	5.6	8.82	16.63	0.15	100
67	113.21		9.07			
514	113.21	5.6	9.14	16.93	0.15	100
515	113.21	5.6	9.38	17.15	0.15	100
516	113.21		9.82			
65	112.58		10.69			
517	112.58	5.6	9.55	17.31	0.15	100
518	112.58	5.6	9.81	17.54	0.15	100
66	112.58		10.65			
519	110.17	5.6	7.82	15.66	0.15	100
520	110.62		11.68			
521	110.17	5.6	7.92	15.76	0.15	100
522	110.62		11.57			
523	110.17	5.6	10.52	18.17	0.15	100
524	112.58		14.82			
525	110.17	5.6	10.64	18.26	0.15	100
526	112.58		14.65			
527	109.17	5.6	15.47	22.03	0.1	196
528	110.5		22.05			
529	109.42	5.6	21.08	25.71	0.1	196
530	110.5		30.14			
500	109.67	5.6	12.25	19.6	0.1	196
501	113.5		16.73			

# Flow Summary - NFPA

Century Fire Sprinklers, Inc.  
Lees Summit JOF\_FS

Page 5  
Date

---

## NODE ANALYSIS (cont.)

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
502	113.5		17.05		
503	113.5		18.02		
504	113.5		20.94		
55	113.5		25.51		
54	110.5		30.68		
53	110.5		30.75		
52	110.5		30.82		
51	110.5		31.94		
50	110.5		37.62		
5	95.5		49.14		
4	94.88		50.03		
3	94.88		50.13		
2	94.88		51.29		
1	95.0		52.87		
BR1	87.0		58.8		
BF	87.0		64.17		
UG	90.0		63.59		
TEST	100.0		61.16	250.0	



# Final Calculations : Hazen-Williams

Century Fire Sprinklers, Inc.  
Lees Summit JOF\_FS

Page 6  
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
505 to 502	109.67 113.5	5.60	19.77 19.77	1 1.049	T 5.0	44.000 5.000 49.000	120 0.1274	12.468 -1.659 6.244		Vel = 7.34	
502			0.0 19.77					17.053		K Factor = 4.79	
506 to 503	109.67 113.5	5.60	20.29 20.29	1 1.049	T 5.0	44.000 5.000 49.000	120 0.1337	13.130 -1.659 6.550		Vel = 7.53	
503			0.0 20.29					18.021		K Factor = 4.78	
507 to 504	109.67 113.5	5.60	21.78 21.78	1 1.049	T 5.0	44.000 5.000 49.000	120 0.1524	15.133 -1.659 7.469		Vel = 8.09	
504			0.0 21.78					20.943		K Factor = 4.76	
508 to 69	113.21 113.21	5.60	16.41 16.41	1.25 1.38	T 6.0	6.320 6.000 12.320	120 0.0238	8.582 0.0 0.293		Vel = 3.52	
69			0.0 16.41					8.875		K Factor = 5.51	
509 to 69	113.21 113.21	5.60	16.44 16.44	1.25 1.442	T 7.432	5.680 7.432 13.112	120 0.0192	8.623 0.0 0.252		Vel = 3.23	
69 to 64	113.21 112.08		16.41 32.85	1.25 1.442	T 7.432	1.120 7.432 8.552	120 0.0692	8.875 0.489 0.592		Vel = 6.45	
64 to 63	112.08 112.08		0.0 32.85	2 2.157		4.020 4.020	120 0.0097	9.956 0.0 0.039		Vel = 2.88	
63 to 62	112.08 112.08		32.92 65.77	2 2.157		4.930 4.930	120 0.0351	9.995 0.0 0.173		Vel = 5.77	
62 to 61	112.08 112.58		33.24 99.01	2 2.157	L 3.692	1.540 3.692 5.232	120 0.0751	10.168 -0.217 0.393		Vel = 8.69	
61 to 60	112.58 112.58		0.0 99.01	2 2.157	L 3.692	9.150 3.692 12.842	120 0.0750	10.344 0.0 0.963		Vel = 8.69	
60 to 59	112.58 112.58		68.93 167.94	2 2.157		4.020 4.020	120 0.1993	11.307 0.0 0.801		Vel = 14.74	
59 to 58	112.58 112.58		31.41 199.35	2 2.157		12.830 12.830	120 0.2736	12.108 0.0 3.510		Vel = 17.50	
58 to 57	112.58 112.58		36.43 235.78	2 2.157	L 3.692	3.970 3.692 7.662	120 0.3731	15.618 0.0 2.859		Vel = 20.70	
57 to 56	112.58 110.5		0.0 235.78	2 2.157	L 3.692	6.820 3.692 10.512	120 0.3732	18.477 0.901 3.923		Vel = 20.70	

# Final Calculations : Hazen-Williams

Century Fire Sprinklers, Inc.  
Lees Summit JOF\_FS

Page 7  
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
56 to 52	110.5 110.5		22.03 257.81	2 2.157	T 12.307	4.780 12.307 17.087	120 0.4403	23.301 0.0 7.523		Vel = 22.64	
52			0.0 257.81					30.824		K Factor = 46.44	
510 to 68	113.21 113.21	5.60	16.47 16.47	1.25 1.442	T 7.432	6.320 7.432 13.752	120 0.0193	8.646 0.0 0.266		Vel = 3.24	
68			0.0 16.47					8.912		K Factor = 5.52	
511 to 68	113.21 113.21	5.60	16.45 16.45	1.25 1.38	T 6.0	5.680 6.000 11.680	120 0.0239	8.633 0.0 0.279		Vel = 3.53	
68 to 63	113.21 112.08		16.47 32.92	1.25 1.442	T 7.432	1.120 7.432 8.552	120 0.0695	8.912 0.489 0.594		Vel = 6.47	
63			0.0 32.92					9.995		K Factor = 10.41	
512 to 67	113.21 113.21	5.60	16.62 16.62	1.25 1.442	T 7.432	6.320 7.432 13.752	120 0.0196	8.804 0.0 0.270		Vel = 3.27	
67			0.0 16.62					9.074		K Factor = 5.52	
513 to 67	113.21 113.21	5.60	16.63 16.63	1.25 1.442	T 7.432	5.680 7.432 13.112	120 0.0196	8.817 0.0 0.257		Vel = 3.27	
67 to 62	113.21 112.08		16.61 33.24	1.25 1.442	T 7.432	1.120 7.432 8.552	120 0.0707	9.074 0.489 0.605		Vel = 6.53	
62			0.0 33.24					10.168		K Factor = 10.42	
514 to 515	113.21 113.21	5.60	16.93 16.93	1.25 1.442		12.000 12.000	120 0.0203	9.137 0.0 0.244		Vel = 3.33	
515 to 516	113.21 113.21	5.60	17.15 34.08	1.25 1.442	L 2.477	3.470 2.477 5.947	120 0.0740	9.381 0.0 0.440		Vel = 6.70	
516 to 65	113.21 112.58		0.0 34.08	1.25 1.442	T 7.432	0.620 7.432 8.052	120 0.0740	9.821 0.273 0.596		Vel = 6.70	
65 to 60	112.58 112.58		34.84 68.92	2 2.157	T 12.307	3.770 12.307 16.077	120 0.0384	10.690 0.0 0.617		Vel = 6.05	
60			0.0 68.92					11.307		K Factor = 20.50	
517 to 518	112.58 112.58	5.60	17.31 17.31	1.25 1.442		12.000 12.000	120 0.0212	9.552 0.0 0.254		Vel = 3.40	

# Final Calculations : Hazen-Williams

Century Fire Sprinklers, Inc.  
Lees Summit JOF\_FS

Page 8  
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
518 to 66	112.58 112.58	5.60	17.53 34.84	1.25 1.442	T	7.432	3.470 7.432 10.902	120	9.806 0.0 0.841		Vel = 6.84	
66 to 65	112.58 112.58		0.0 34.84	2			4.000	120	10.647 0.0 0.043		Vel = 3.06	
65			0.0 34.84						10.690		K Factor = 10.66	
519 to 520	110.17 110.62	5.60	15.66 15.66	1 1.049	T	5.0	44.000 5.000 49.000	120	7.820 -0.195 4.055		Vel = 5.81	
520 to 59	110.62 112.58		15.76 31.42	1.25 1.442	2E T	7.432	5.170 7.432 14.864 20.034	120	11.680 -0.849 1.277		Vel = 6.17	
59			0.0 31.42						12.108		K Factor = 9.03	
521 to 522	110.17 110.62	5.60	15.76 15.76	1 1.049	E	2.0	44.000 2.000 46.000	120	7.917 -0.195 3.851		Vel = 5.85	
522 to 520	110.62 110.62		0.0 15.76	1.25			6.000	120	11.573 0.0 0.107		Vel = 3.10	
520			0.0 15.76						11.680		K Factor = 4.61	
523 to 524	110.17 112.58	5.60	18.17 18.17	1 1.049	T	5.0	44.000 5.000 49.000	120	10.523 -1.044 5.338		Vel = 6.75	
524 to 58	112.58 112.58		18.26 36.43	1.25 1.442	T	7.432	2.130 7.432 9.562	120	14.817 0.0 0.801		Vel = 7.16	
58			0.0 36.43						15.618		K Factor = 9.22	
525 to 526	110.17 112.58	5.60	18.26 18.26	1 1.049	E	2.0	44.000 2.000 46.000	120	10.635 -1.044 5.060		Vel = 6.78	
526 to 524	112.58 112.58		0.0 18.26	1.25			7.080	120	14.651 0.0 0.166		Vel = 3.59	
524			0.0 18.26						14.817		K Factor = 4.74	
527 to 528	109.17 110.5	5.60	22.03 22.03	1 1.049	E	2.0	44.000 2.000 46.000	120	15.474 -0.576 7.157		Vel = 8.18	
528 to 56	110.5 110.5		0.0 22.03	1 1.049	T	5.0	3.010 5.000 8.010	120	22.055 0.0 1.246		Vel = 8.18	
			0.0									

# Final Calculations : Hazen-Williams

Century Fire Sprinklers, Inc.  
Lees Summit JOF\_FS

Page 9  
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
56			22.03						23.301		K Factor = 4.56	
529 to 530	109.42 110.5	5.60	25.71	1	E	2.0	44.000 2.000	120	21.077 -0.468			
530 to 53	110.5 110.5		25.71	1.049			46.000	0.2071	9.526		Vel = 9.54	
530 to 53	110.5 110.5		0.0	1.25	T	7.432	6.510 7.432	120	30.135 0.0			
53			25.71	1.442			13.942	0.0440	0.613		Vel = 5.05	
53			0.0 25.71						30.748		K Factor = 4.64	
500 to 501	109.67 113.5	5.60	19.60	1	T	5.0	44.000 5.000	120	12.250 -1.659			
501 to 502	113.5 113.5		19.6	1.049			49.000	0.1254	6.143		Vel = 7.28	
501 to 502	113.5 113.5		0.0	1.25			12.000	120	16.734 0.0			
502 to 503	113.5 113.5		19.6	1.442			12.000	0.0266	0.319		Vel = 3.85	
502 to 503	113.5 113.5		19.77	1.25			10.000	120	17.053 0.0			
503 to 504	113.5 113.5		39.37	1.442			10.000	0.0968	0.968		Vel = 7.73	
503 to 504	113.5 113.5		20.30	1.25			14.000	120	18.021 0.0			
504 to 55	113.5 113.5		59.67	1.442			14.000	0.2087	2.922		Vel = 11.72	
504 to 55	113.5 113.5		21.78	1.25	L	2.477	9.820 2.477	120	20.943 0.0			
55 to 54	113.5 110.5		81.45	1.442			12.297	0.3712	4.565		Vel = 16.00	
55 to 54	113.5 110.5		0.0	1.25	T	7.432	3.000 7.432	120	25.508 1.299			
54 to 53	110.5 110.5		81.45	1.442			10.432	0.3713	3.873		Vel = 16.00	
54 to 53	110.5 110.5		0.0	3			9.830	120	30.680 0.0			
53 to 52	110.5 110.5		81.45	3.26			9.830	0.0069	0.068		Vel = 3.13	
53 to 52	110.5 110.5		25.71	3			6.500	120	30.748 0.0			
52 to 51	110.5 110.5		107.16	3.26			6.500	0.0117	0.076		Vel = 4.12	
52 to 51	110.5 110.5		257.81	3			10.000	120	30.824 0.0			
51 to 50	110.5 110.5		364.97	3.26			10.000	0.1120	1.120		Vel = 14.03	
51 to 50	110.5 110.5		0.0	3	T	20.159	17.020 33.599	120	31.944 0.0			
50 to 5	110.5 95.5		364.97	3.26	L	6.72	18.000 26.879	120	37.617 6.496			
50 to 5	110.5 95.5		0.0	3	T	20.159	26.879 44.879	120	5.030		Vel = 14.03	
5			0.0 364.97						49.143		K Factor = 52.06	
5 to 4	95.5 94.88		364.97	4	2L	15.8	4.600 15.800	120	49.143 0.269			
4 to 3	94.88 94.88		364.97	4.26			20.400	0.0304	0.620		Vel = 8.22	
4 to 3	94.88 94.88		0.0	4			3.280	120	50.032 0.0			
4 to 3	94.88 94.88		364.97	4.26			3.280	0.0305	0.100		Vel = 8.22	

# Final Calculations : Hazen-Williams

Century Fire Sprinklers, Inc.  
Lees Summit JOF\_FS

Page 10  
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
3 to 2	94.88 94.88		0.0 364.97	4 4.26	L 7.9	30.000 7.900 37.900	120 0.0304	50.132 0.0 1.154		Vel = 8.22	
2 to 1	94.88 95		0.0 364.97	4 4.26	3L 23.701	30.000 23.701 53.701	120 0.0305	51.286 -0.052 1.636		Vel = 8.22	
1 to BR1	95 87		0.0 364.97	4 4.26	B S T 15.8 28.968 26.334	10.000 71.102 81.102	120 0.0304	52.870 3.465 2.469		Vel = 8.22	
BR1 to BF	87 87		0.0 364.97	4 4.26	Zca 0.0	1.000 1.000	120 0.0300	58.804 5.332 0.030		** Fixed Loss = 5.332 Vel = 8.22	
BF to UG	87 90		0.0 364.97	4 4.26	2L 15.8	8.000 15.800 23.800	120 0.0305	64.166 -1.299 0.725		Vel = 8.22	
UG to TEST	90 100		0.0 364.97	6 6.16	4L T G 51.645 43.037 4.304	400.000 98.986 498.986	140 0.0038	63.592 -4.331 1.896		Vel = 3.93	
TEST			250.00 614.97					61.157		Qa = 250.00 K Factor = 78.64	