

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20232768  
Address: 810 NW WARD RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Miscellaneous Inspection</b>	Robb Popp	Partial	Thursday, June 12, 2025

Corrective Action Required:

1	Misc	G pre final -Install smoke seals at corridor doors 4th floor: 2425- seal fire sprinkler sconce in front hallway 2427- missing fire sprinkler sconce in living room 2432 - receptacle not GFCI protected kitchen counter far left of refrigerator  3rd Floor: 2324-Install smoke seal at entry door, tape drywall at mech room ceiling 2327-Secure dishwasher discharge line above bowl of sink 2329-GFCI protection required within 6' of kitchen sink MEP ROOM- Seal penetrations, install knockout cover at ceiling J box, install smoke seals 2332- Smoke detector not permitted within 6' of range 2334-GFCI at laundry not working, must also be AFCI
---	------	---

**Comments:**