

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20242356  
Address: 221 NE ALURA WAY, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                      | Inspector:  | Outcome: | Date:                 |
|----------------------------------|-------------|----------|-----------------------|
| <b>Sanitary Sewer - Air Test</b> | Devon Perry | Passed   | Friday, June 13, 2025 |

Informational:  
1 Misc 6-12-25 DP. Advanced Excavation came back onsite and tested today. Air pressure test passed passed. It held for the required 7 minutes 34 seconds.

**Comments:**