



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20116335, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Wednesday, February 08, 2012

Partial Correction
1 MISC

OK TO COVER WHEN READY WALL FRAMING & IN-WALL SYSTEMS AT 077 AFTER PUTTY PAD IS COMPLETED AT WEST WALL; 68A, 69A, 69B, 69C, 69D AFTER TWO ELECTRICAL BOXES ARE PUTTY-PADDED PER DISCUSSION

Above Ceiling Inspection	John Borns	Partial	Wednesday, February 08, 2012
---------------------------------	------------	---------	------------------------------

Partial Correction
1 MISC

OK TO COVER WHEN READY GYP BOARD CEILING FRAMING AND ABOVE-CEILING SYSTEMS AT: 077 AFTER TEMPORARY ELECTRICAL WIRING IS REMOVED;

Comments: