

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20240118  
Address: 515 NW MOORE ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Robb Popp	Partial	Friday, June 13, 2025

Informational:

1	Misc	-Corridor ceiling joist space ok for RC all floors
---	------	----------------------------------------------------

Corrective Action Required:

2	Misc	*Inspection for soffit framing at atriums: 2nd, 3rd and 4th floor ok to cover
---	------	----------------------------------------------------------------------------------

4th floor corridor  
-Remove tiles for inspection  
-Seal penetrations  
-Complete water line by elevator  
-label wall

3rd floor  
-seal penetrations

**Comments:**