

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250844
Address: 2611 SW FIREFLY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Drew Fischer	Failed	Friday, June 13, 2025

Informational:

1	Misc	garage portal frame ok back porch ok to cover
---	------	--

Corrective Action Required:

2	Misc	2611 SW Firefly Ln - Fire blocking at left end of fireplace bump out - Fire blocking in bedroom 2 closet, where wires go to attic by the screen porch door - 2 king studs required at each end of window unit at back wall of great room -
---	------	--

Comments: