



302 Campusview Drive, Suite 208  
Columbia, MO 65201  
573-256-7200



## Addendum 2

**Alura – Village at Discovery Park  
Lee’s Summit, MO  
Wallace Job 4938**

**June 13, 2025**

The following are deletions, additions and/or clarifications to the Plans and shall be considered as if originally contained therein:

### **Architectural Drawing Clarifications prepared by Wallace Architects, LLC (Revisions attached):**

#### 0.0M

1. The Master Cover Index to Drawings has been revised to reflect current Drawing Sheet Titles and Dates consistent with the affected Drawing Sheets added/revised as part of this Addendum.

#### **Garage Building Type “D”**

#### 0.0GD

1. The Index to Drawings has been revised to reflect current Drawing Sheet Titles and Dates consistent with the affected Drawing Sheets added/revised as part of this Addendum.

#### A1.0GD

1. Section marker for the newly added section 13/A4.0GD (attic draftstopping) has been added to Drawing 1.

#### A2.0GD

1. Draftstopping location has been added to Drawing 2 and attic access locations revised accordingly.
2. Attic Draftstopping Door, Drawing 3 has been added in its entirety and tagged accordingly.

#### A4.0GD

1. Wall Section at Draftstopping, Drawing 13 has been added in its entirety to show draftstopping to coordinate with revisions on the Roof Plan.

## **Pool House**

### 0.0P

1. The Index to Drawings has been revised to reflect current Drawing Sheet Titles and Dates consistent with the affected Drawing Sheets added/revised as part of this Addendum.

### A1.0P

1. Mop sink has been added to Drawing 1 including note for FRP panels 4' tall and within 2' of mop sink.
2. Dual height, water fountain has been added to Drawing 1.

### A1.1P

1. Drawing 1 has been revised to coordinate with the addition of the water fountain and mop sink on the Pool House Dimension Plan.

### A6.0P

1. Drawing 1 has been revised to coordinate with the addition of the water fountain and mop sink on the Pool House Dimension Plan.

### A7.0P

1. Drawing 13, Water Fountain Detail, has been added in its entirety.

## **MEP Drawing Clarifications, prepared by J-Squared Engineering (Revisions attached):**

## **Pool House**

### E101, P101

1. Sheets have been revised to coordinate with Architectural Plan revisions to include a water fountain and mop sink.

## **Attachments:**

1. The following 24" x 36" Architectural Drawing Sheets, prepared by Wallace Architects, LLC, are being reissued (labeled as Addendum #2, clouded with a Delta 2 and bearing a latest revision date of 13 JUN 2025):

0.0M

### **Garage Bldg. Type "D"**

0.0GD

A1.0GD

A2.0GD

A4.0GD

**Pool House**

0.0P  
A1.0P  
A1.1P  
A6.0P  
A7.0P

2. The following 24" x 36" MEP Drawing Sheets, prepared by J-Squared Engineering, are being reissued (labeled as Addendum 2, clouded with a Delta 2 and bearing a latest revision date of 06-13-2025):

**Pool House**

E101  
P101

END OF ADDENDUM 2