



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20112915
Address: 80 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086
Inspected On: Thursday, February 09, 2012
Inspected By: John Borns
Expiration Date: 3/1/2012 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Thursday, February 09, 2012

Corrective Action Required:

1 MISC RESOLVE FIRE DEPARTMENT ISSUES

Corrective Action Required:

2 MISC RESOLVE PLANNING & DEVELOPMENT ISSUES

Corrective Action Required:

3 MISC RESOLVE PUBLIC WORKS ISSUES. ENSURE RUNOFF IS PREVENTED PER PUBLIC WORKS REQUIREMENTS PENDING SODDING AND COMPLETION OF FINISH SITEWORK.

Corrective Action Required:

4 MISC PANIC HARDWARE TO BE INSTALLED AT STEEL GATE ON EGRESS PATH OUTSIDE NORTH WALL OF BUILDING ADDITION.

Corrective Action Required:

5 MISC ROOFTOP LIGHTNING PROTECTION TO BE INSTALLED/RESTORED.

Corrective Action Required:

6	MISC	WHEN ALL ROOFTOP WORK IS COMPLETED ENSURE ALL DEBRIS AND UNUSED MATERIAL IS REMOVED FROM ROOFTOP AND FROM ROOF DRAINS.
---	------	------------------------------------------------------------------------------------------------------------------------------

Comments: EXTEND TCO PER TURNER CONSTR REQUEST.