

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOMCOM20240778  
Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Shawn Hoffman	Partial	Monday, June 16, 2025

Corrective Action Required:  
1 ELEVATOR 1 approved areas  
shaft liner  
first layer back side  
first layer hat  
Outside elevator all sides

Corrective Action Required:  
2 Misc screw pattern of sheet rock on door side both levels approved.

**Comments:**