

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242665
Address: 3804 SW RAVENGATE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Dustin Agcopra	Partial	Monday, June 16, 2025

Corrective Action Required:

1	Misc	10-13-24 Dustin A, SW in front has been poured to city specs, still needs sw on north side 6-16-25 Dustin A, Last section is formed and compacted and slopes are in compliance at this time, approved to pour
---	------	--

Comments: