

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244003

Address: 225 NW ORCHARD CT, LEES SUMMIT, MO 64063223 NW ORCHARD CT, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Robb Popp	Failed	Monday, June 16, 2025

Corrective Action Required:

1	DCM3 ESC REQUIRED 2 DAY	6/16/25 EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. -Maintain gravel filter with min 6" lift of min 3/4" gravel -Post address -Properly protect storm inlet -Maintain overgrown vegetation
---	----------------------------	---

Comments: