

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20244002

Address: 219 NW ORCHARD CT, LEES SUMMIT, MO 64063219 NW ORCHARD CT, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection Residential</b>	Robb Popp	Failed	Monday, June 16, 2025

**Corrective Action Required:**

1	DCM3 ESC REQUIRED 2 DAY	6/16/25 EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. -Maintain gravel filter with min 6" lift of min 3/4" gravel -Post address -Properly protect storm inlets -Maintain overgrown vegetation
---	----------------------------	--

**Comments:**