CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20246440

Address: 2769 SW 12TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Shawn Hoffman Ready for Temp CO Monday, June 16, 2025

Residential

Corrective Action Required:

1 Misc - Pay all fees

- final grading and sod

- Sump discharge to be 36" away from foundation

Provide splash pads at down spoutsSeal exterior penetration at gas piping

- Driveway and sidewalk inspections pending

Comments: