

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240700

Address: 207 NW ORCHARD CT, LEES SUMMIT, MO 64063205 NW ORCHARD CT, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Partial	Monday, June 16, 2025

Informational:

1 Misc

*6/16/25

Status of permit inspections:

-All rough inspection passed

-Rated assembly inspection failed (as noted on report dated 1/27/25)

Corrections are as noted-

-Unit 205 approved

Unit 207- firetape attic space, seal all gaps and penetrations

**Last activity is Driveway inspection passed on 3/26/25

Comments: