

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20250050  
Address: 1059 SW FIORD DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Shawn Hoffman	Ready for Temp CO	Monday, June 16, 2025

### Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>- perform final grading and sod</li><li>- sump discharge to be 36" away from foundation</li><li>-address pending driveway and sidewalk inspections</li><li>-pay fees</li><li>- provide splash pads at down spouts</li><li>- Land sewer trace wire at grade</li></ul>
---	------	--

### Comments: