



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20111185, Building Permit - Commercial
Address: 1041 NE SAM WALTON LN, Unit:A, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Thursday, February 09, 2012

Partial Correction
1 MISC

OK TO COVER WHEN READY WALL FRAMING AND IN-WALL SYSTEMS AT: N DEMMISING WALL; 101 SE CORNER + WEST WALL; 103; 104;

Underslab Electrical Inspection - Commercial	John Borns	Passed	Thursday, February 09, 2012
---	------------	--------	-----------------------------

Comments: OK TO COVER WHEN READY TWO 1" + ONE 3/4" PVC UNDER-SLAB CONDUITS AT CASH WRAP