



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No: PRCOM20244755 Date: June 17, 2025
Project Title: FLEX SPACES LEE'S SUMMIT - BUILDING B Applicant:
Location: ALLIANCE FIRE PROTECTION LLC
60 SE THOMPSON DR, Unit:B, LEES SUMMIT, MO 64082 130 W 9TH AVE STE 101
Type of Work: KANSAS CITY, MO 64116
Occupancy Group: F-1 Primary: (913) 888-0647
Description: NORTH BUILDING B- FLEX SPACE -
NEW BUILDING WITH SPACES TO RENT FOR
CONTRACTOR GARAGES
Construction Type: Type IIB (Unprotected)
Map Page:

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Craig Hill

Released for Construction

Sprinkler Plan Review

Reviewed By: Craig Hill

Rejected

1. Action Required: Move fire department connection to the west side of the building
2. Action Required: FDC needs to be a 4" storz connection with a 30-degree elbow.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.