

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSITE20235732

Address: 1901 NE TRAILS EDGE BLVD, LEES SUMMIT, MO 640641921 NE TRAILS EDGE BLVD, LEES SUMMIT, MO 640642001 NE TRAILS EDGE BLVD, LEES SUMMIT, MO 640642021 NE TRAILS EDGE BLVD, LEES SUMMIT, MO 640642031 NE TRAILS EDGE BLVD, LEES SUMMIT, MO 640642 NE ALURA WAY, LEES SUMMIT, MO 640641900 NE DISCOVERY AVE, LEES SUMMIT, MO 640641920 NE DISCOVERY AVE, LEES SUMMIT, MO 640641901 NE DISCOVERY AVE, LEES SUMMIT, MO 640641921 NE DISCOVERY AVE, LEES SUMMIT, MO 64064100 NE ALURA WAY, LEES SUMMIT, MO 64064200 NE ALURA WAY, LEES SUMMIT, MO 64064251 NE ALURA WAY, LEES SUMMIT, MO 64064250 NE ALURA WAY, LEES SUMMIT, MO 64064221 NE ALURA WAY, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                 | Inspector:  | Outcome: | Date:                    |
|---|-------------|----------|--------------------------|
| <b>Water Line - Construction Inspection</b> | Devon Perry | Partial  | Wednesday, June 18, 2025 |

Informational:

1 Misc

5-7-25 DP. Sapp is onsite working on water line C.

5-30-25 DP. Seth with ESS is onsite continuing on with the private water which works towards public line C

6-13-25 DP. Private water line 1 is installed, hydrostatic passed at 150psi for 2 hours and line was chlorinated.

**Comments:**