

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20251486  
Address: 1043 SW FIORD DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Not Ready	Wednesday, June 18, 2025

Corrective Action Required:

1	Misc	PORTAL FRAME AND FRON PORCH ONLY
		- Missing LUS24 hangers on trusses at front porch
		- Sheeting at portal frame approved
		- Straps missing on inside ( will re inspect at all rough)

Corrective Action Required:

2	Misc	NOT READY
		- No fire blocking done
		- No plans on sight

**Comments:**