



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20111185, Building Permit - Commercial  
Address: 1041 NE SAM WALTON LN, Unit:A, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Failed	Friday, February 10, 2012

Corrective Action Required  
1 MISC

DEMISING WALL SOUTH FACE SCREWS NOT AT 8" AT PERMETER & 12" IN THE FIELD AT ALL LOCATIONS

**Comments:**