

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20251365  
Address: 1047 SW FIORD DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection</b>	Shawn Hoffman	Failed	Friday, June 20, 2025

**Corrective Action Required:**

- |   |      |   |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none"><li>- provide truss hold downs above garage doors</li><li>- Fire block soffit both ends at back garage wall</li><li>- Plans call for 5 studs under I-beam at garage/ coat room</li><li>- 2 joist cut and landing on non load bearing wall in kitchen at HVAC chase</li><li>- Missing studs at hallway and back garage corner</li><li>- Solid block sheeting break of gable above primary bedroom</li><li>- Fire block top plate at double wall primary tub/ closet</li><li>- 3 studs required at all exterior wall corners, at basement cripple walls both sides</li><li>- Nail off siding at gas meter at cripple wall overlap</li></ul> |
|---|------|---|

**Comments:**