

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20251486
Address: 1043 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Not Ready	Friday, June 20, 2025

Corrective Action Required:	
1 Misc	PORTAL FRAME AND FRON PORCH ONLY
	- Missing LUS24 hangers on trusses at front porch
	- Sheeting at portal frame approved
	- Straps missing on inside (will re inspect at all rough)

Corrective Action Required:	
2 Misc	NOT READY
	- No fire blocking done
	- No plans on sight
Corrective Action Required:	
3 Misc	INSPECTION DENIED
	NO PLANS IN LOCATION

Comments: