



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20113727, Building Permit - Commercial
Address: 2741 NE MCBAIN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Tuesday, February 14, 2012

Corrective Action Required
1 MISC

OK TO DROP TILES AT FOLLOWING SPACES EXCEPT LEAVE OUT TILE TO PROVIDE VIEW FROM FLOOR OF HVAC FLEX CONNECTORS TO DIFFUSERS WHICH MUST BE SECURED AT INNER LAYER AND AT OUTER LAYER PER AIR DIFFUSION COUNCIL/SMACNA: 107-111; 113; 116; 118-124; 127; 130;

Comments: