

CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX:

816-969-1201

Inspection Summary

Permit #: PRCOM20111185, Building Permit - Commercial

Address: 1041 NE SAM WALTON LN, Unit:A, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Underslab Plumbing John Borns Partial Tuesday, February 14, 2012

Inspection - Commercial

Partial Correction

1 MISC OK TO COVER WHEN READY UNDER-SLAB WASTE PIPING AND

FIXTURE STUB-UPS AT SUITE "A"; ALSO, 4" BUILDING DRAIN NORTH TO CONNECTION TO EXISTING IN SUITE "B". FIXTURE STUB-UPS AT SUITE "B" SOUTHWEST @ NEW WALL NOT SHOWN ON APPROVED DRAWINGS -- NOT APPROVED.

Comments: