

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20246285

Address: 1333 SW WINTHROP TER, LEES SUMMIT, MO 640811331 SW WINTHROP TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Tuesday, June 24, 2025

Corrective Action Required:

1 Misc

Both sides

-address rafter to ceiling joist connections (N and S walls)  
-

1331

-fire block around beam N wall in basement  
-tighten anchor bolts where loose throughout basement  
-fireblock bed 4 S wall into furr down  
-bond gas line

1333

-seal penetrations in roof decking  
-address gas pressure not at minimum

**Comments:**