

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20242774  
Address: 1000 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Robb Popp	Failed	Tuesday, June 24, 2025

Corrective Action Required:

1	Misc	(4) interior footings from north end south 60' to first step down
---	------	---

\*\*6/23/25 Not ready

\*\*6/24/25 - Complete corner steel, provide proper clearance at earth and to foam, remove trash and loose soil

**Comments:**