

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20243938
Address: 1921 NE TRAILS EDGE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Wye / Insert-A-Tee Installation	Dustin Agcopra	Failed	Tuesday, June 24, 2025

Corrective Action Required:

1	Misc	6-24-25 Dustin A, Wrong kind of fernco was used for sewer stub connection. Contractor will reach out when corrected for reinspection.
---	------	--

Comments: