

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232768
Address: 810 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Partial	Tuesday, June 24, 2025

Corrective Action Required:

1	Misc	G pre final -Install smoke seals at corridor doors
		4th floor: OK
		3rd Floor: MEP Seal penetrations
		2nd floor: -Electrical room-provide signage, label panel, provide panel
		1st floor units only MEP-Seal penetration at wall 212-combo detector required outside of bedroom MEP-Tighten pans around HVAC to ceiling

Comments: