

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOMCOM20240340
Address: 1923 NE DISCOVERY AVE, LEES SUMMIT, MO 64064 1921 NE DISCOVERY AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Khanh Nguyen	Partial	Tuesday, June 24, 2025

Informational:

1	Misc	Exterior footing OK: -7.7/F.9 to 10.4/F.9 to 13/D.9; D.2/12.5-7.5-5.1; D.2/5.1 to elevator; other side of elevator to G/5.1 -Cont. from 7.7/F.9 to 6.5/F.9; area 5.5/F.9 to 6.5/F.1 (rm 1003-1006); cont. to 6/D.9; 4.3/D.3-B.4; -B/5 to A.1/5 to A/1 to D.4/1 to G/2.2 to G/5.1 -F. wall from G/5.1 to elevator; D.35/5.1 to elevator; G/2.2-4.3 -P19 @ G/5.1 -East stair tower pad and f. wall -West stair tower pad and f. wall -Elevator pad and f. wall and pedestals -Col ftg D.9/6.5-12 and F.1/7-12; B-F/2-3 -Pedestals D.9/6.5-12 and F.1/7-12
---	------	---

Comments: