

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250690
Address: 2237 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Wednesday, June 25, 2025

Corrective Action Required:

1	Misc	6/25/25 Inspection for "Need inspection on garage door portal framing, front porch ceiling and back deck ceiling only" -PFH- seal nail penetrations in moisture barrier -Front ceiling - OK to cover -Back porch ceiling- Already covered -Back CS-PF - Complete nailing pattern at exterior
---	------	---

Comments: