

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242856

Address: 1414 SW WINTHROP TER, LEES SUMMIT, MO 640811412 SW WINTHROP TER, LEES SUMMIT, MO
64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, June 25, 2025

Corrective Action Required:

1	Misc	Both sides -Address pending driveway inspection -Sod -all circuits in kitchen must be AFCI protected -laundry circuit must be afci protected
---	------	--

Comments: