

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20244827

Address: 1415 SW WINTHROP TER, LEES SUMMIT, MO 640811413 SW WINTHROP TER, LEES SUMMIT, MO  
64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                     | Inspector:       | Outcome: | Date:                    |
|-------------------------------------------------|------------------|----------|--------------------------|
| <b>Occupancy Inspection - Codes Residential</b> | Mitchell Schwarz | Failed   | Wednesday, June 25, 2025 |

Corrective Action Required:

1 Misc

- Address pending driveway inspection
- Sod  
1413
- open neutral front stoop  
1415
- combiner plug not allowed at sump pump

**Comments:**