

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242857

Address: 1420 SW WINTHROP TER, LEES SUMMIT, MO 640811418 SW WINTHROP TER, LEES SUMMIT, MO
64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, June 25, 2025

Corrective Action Required:

1 Misc

-Address pending driveway inspection
-afci protection required for kitchen and laundry circuits

1420
-remove combination plug at sump pump

Comments: