

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232768
Address: 810 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Shawn Hoffman	Partial	Wednesday, June 25, 2025

Corrective Action Required:

1	Misc	G pre final -Install smoke seals at corridor doors 4th floor: OK 3rd Floor: OK 2nd floor: -Electrical room-provide signage, - garages and storage garage: OK 1st floor units only 2 garages door opener not tied to smoke alarm
---	------	---

Comments: