

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRCOM20242774
Address: 1000 NW PRYOR RD, LEES SUMMIT, MO 64081

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Robb Popp	Failed - Stop Work	Wednesday, June 25, 2025

Corrective Action Required
1 Misc

(4) interior footings from north end south 60' to first step down

****6/23/25** Not ready

****6/24/25** - Complete corner steel, provide proper clearance at earth and to foam, remove trash and loose soil

****6/25/25** Footing poured with no approval. Stop work order issued

Comments: