

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20246085
Address: 3203 SW ENOCH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|--------------------------|
| All Rough Inspection - Residential | Drew Fischer | Failed | Wednesday, June 25, 2025 |

Informational:

| | | |
|---|------|--|
| 1 | Misc | -Garage portal exterior nailing-okay -Cover porch and patio roof framing-okay |
|---|------|--|

Corrective Action Required:

| | | |
|---|------|--|
| 2 | Misc | 3203 SW Enoch - Fire blocking around drain pipe in chase at corner of garage/ kitchen wall - 2 king studs required at each end of windows in master bedroom - |
|---|------|--|

Comments: