

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242858

Address: 1426 SW WINTHROP TER, LEES SUMMIT, MO 640811424 SW WINTHROP TER, LEES SUMMIT, MO
64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, June 25, 2025

Corrective Action Required:

1 Misc

-label electric meter disconnects
-afci protection required for all kitchen and laundry circuits

1426
-plug splitter at sump pump not allowed

Comments: