

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20246426
Address: 1460 SE BROADWAY DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Coliform Test 1	Dustin Agcopra	Passed	Wednesday, June 25, 2025

Informational:
1 Misc 06-09-25 Jamie S, Preformed water sample at site, and delivered to Blue Valley Labs.
6-24-25 Dustin A, Water sample 1 has passed

Comments: