

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20246297
Address: 2607 NE WOODLAND OAK DR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|-------------------------------------------|--------------|----------|-------------------------|
| All Rough Inspection - Residential | Khanh Nguyen | Failed | Thursday, June 26, 2025 |

Corrective Action Required:

| | | |
|---|------|---------------------------------------------------------------------------------------------------|
| 1 | Misc | -Attach deck beam to each post with two 1/2" through bolts/washers/nuts or equivalent connections |
| | | -Windows at rear dining exterior wall shall be safety tempered windows |
| | | **Provide vapor barrier |

Comments: