

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20251250
Address: 2761 SW 11TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Thursday, June 26, 2025

Corrective Action Required:

2	Misc	<ul style="list-style-type: none">- Provide H2.5 hanger at double girder truss at single bay garage door (requires 1 for each truss)- Missing hold downs at bed3 double girder truss- Fire block top of chase dining/ garage- Address cut out too plate at dining/ garage wall and fire block end of soffit- Provide LSTA18 straps at stairs to second floor- Provide hold downs for double girder truss in bed 4 to foyer both ends- Unable to inspect front porch framing and required truss hanger (covered)- Remove gravel from street and curb (on erosion inspection)
---	------	--

Comments: